

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 970/mr

Dated: 24/05/2023

It is Certified that an inspection team headed by RAHUL KR. SINGH, Sanitary Incharge (name of Officers with designation) from NAGAR NIGAM, MUNGER (Name of Department / office) inspected the NEW ERA PUBLIC SCHOOL, PIPALPANTI ROAD, MUNGER (Name & Address of the school) on 15/05/2023 (date of inspection) and found that the NEW ERA PUBLIC SCHOOL MUNGER (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

The above is valid for a period of 01 year.

Signature with Seal: Km Kumari

MAYOR
NAGAR NIGAM, MUNGER

Name: Mrs. Kumkum DeviDesignation: MAYORName & Address of Department / Office: NAGAR NIGAM, MUNGER


To

NEW ERA PUBLIC SCHOOL

PIPALPANTI ROAD, MUNGER

(Name & Address of the Institution)

ATTESTED


SECRETARY
NEW ERA PUBLIC SCHOOL
PIPALPANTI ROAD, MUNGER

ATTESTED


Principal
NEW ERA PUBLIC SCHOOL
Pipalpanti Road, Munger

कार्यपालक अभियंता का कार्यालय
लोक स्वास्थ्य प्रमंडल, मुंगेर।
पत्रांक 2816 / दिनांक 8/12/22

प्रेषक :-

कार्यपालक अभियंता
लोक स्वास्थ्य प्रमंडल
मुंगेर।

सेवा में,

Principal
New Era Public School
Pipal Panti Road, Munger

विषय :- जल जाँच प्रतिवेदन के संबंध में।


प्रसंग:- आपके द्वारा आवेदन संख्या 1075/22 दिनांक 03.12.2022

महाशय,

उपरोक्त प्रासंगिक पत्र के आलोक में New Era Public School Munger के पेजजल के नमूना की जाँच जिला जल जाँच प्रयोगशाला में किया गया जिसमें पेजजल की गुणवत्ता संतोषप्रद पायी गयी।


अनुलग्नक: यथोपरि।

ATTESTED




SECRETARY
NEW ERA PUBLIC SCHOOL
PIPALPANTI ROAD, MUNGER

विश्वासभाजन


कार्यपालक अभियंता

लोक स्वास्थ्य प्रमंडल, मुंगेर।


08.12.2022

ATTESTED



Principal
NEW ERA PUBLIC SCHOOL
Pipalpanti Road, Munger

Government of Bihar
District Level Water Testing Laboratory
Public Health Engineering Department Munger

Sample collected by school staff
District Munger

Month December 2022

Particulars						Test Result (in mg/l)															
Sl. No.	Block Name	Panchayat Name	Village	Ward No.	Name of School	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Fe	Alk	NO ₃	SO ₄	F	As (in ppb)	Total Coliform (MPN count.)	Remarks (Safe/unsafe)
1	Munger Sadar	Municipal Area	Pipal Panti Road	NA	New Era Public School, Munger	7.03	0.4	330	212	170	36	17	28	0.10	150	0	0	0.3	BDL	_ve	
Desirable Limit						6.5-8.5	5	-	500	200	75	30	250	1.00	200	45	200	1.00	0.010	0/100ml	
Maximum Permissible Limit						NR	10		2000	600	200	150	1000	NR	600	NR	400	1.50	NR	NR	

Note- 1. All parameter tested in this laboratory are found within the maximum permissible limit.

2. NR- (Not Relaxable)

3. BDL- Below Detection Limit.

Refined
For Chemist
PH Division, Munger
02/12/2022

ATTESTED

[Signature]
SECRETARY
NEW ERA PUBLIC SCHOOL
PIPALPANTI ROAD, MUNGER

ATTESTED



[Signature]
Principal
NEW ERA PUBLIC SCHOOL
Pipalpanti Road, Munger